

# DRINKING *(Finished Product)*

## Water Analysis Report

Testing Period: July 2022 - September 2022

**3<sup>rd</sup> Quarter 2022**

Analyte	Analyte RESULT	MCL (mg/L) (Maximum Contaminant Level)
Bromate	BDL	0.010
Nitrate	BDL	10.0
Nitrite	BDL	1.0
Alkalinity	BDL	100.0
Alkalinity, Bicarbonate	BDL	100.0
Hardness	BDL	80.0
Calcium	2.48	None
Lead	BDL	0.015
Magnesium	BDL	2.0
Potassium	BDL	1.0
Sodium	BDL	250.0
Chloride	BDL	250.0
Fluoride	BDL	2.0
Sulfate	BDL	250.0
Dissolved Solids	BDL	500.0
Copper	BDL	1.0
Arsenic	BDL	0.010
pH	7.02	6.5 - 8.5
Aluminum	BDL	0.05 to 0.02
Iron	BDL	0.3
Manganese	BDL	0.05
Silver	BDL	0.10
Zinc	BDL	5.0
Color	BDL	15.0
Odor	BDL	3.0
MBAS	BDL	0.50

*BDL = Below Detection Limit*

