

# DRINKING *(Finished Product)*

## Water Analysis Report

Testing Period: January 2026 - March 2026

**1<sup>st</sup> Quarter 2026**

Analyte	Analyte RESULT	MCL (mg/L) (Maximum Contaminant Level)
Bromate	BDL	0.010
Nitrate	BDL	10.0
Nitrite	BDL	1.0
Alkalinity	BDL	100.0
Alkalinity, Bicarbonate	BDL	100.0
Hardness	BDL	80.0
Calcium	BDL	None
pH	7.09	6.5-8.5
Lead	BDL	0.015
Magnesium	BDL	2.0
Potassium	BDL	1.0
Sodium	BDL	250.0
Chloride	BDL	250.0
Fluoride	BDL	2.0
Sulfate	BDL	250.0
Dissolved Solids	BDL	500.0
Copper	BDL	1.0
Arsenic	BDL	0.010
Cyanide	BDL	0.2
Mercury	BDL	0.002
Barium	BDL	2.0
Chromium	BDL	0.10
Nickel	BDL	0.10
Antimony	BDL	0.006
Cadmium	BDL	0.005
Selenium	BDL	0.05
Thallium	BDL	0.002
Beryllium	BDL	0.004
Aluminum	BDL	0.05 to 0.02
Iron	BDL	0.3
Manganese	BDL	0.05
Silver	BDL	0.10
Zinc	BDL	5.0
Color	BDL	15.0
Odor	BDL	3.0
MBAS	BDL	0.50

*BDL = Below Detection Limit*

